

RESIDUAL-CURRENT DEVICE COMPON.SUMMATION  
 CURR.TRANSF. W/O PICK-UP DELAY WINDOW 40MM  
 RTD.FAULT CURRENT 1A



Figure similar

General technical data:	
Product designation	summation current transformer for residual current monitoring
Product feature Touch protection	Yes
Type of electrical connection at output	screw-type terminals
Fault current at input rated value	1 A
Equipment marking acc. to DIN EN 81346-2	B
Equipment marking acc. to DIN 40719 extended according to IEC 204-2 acc. to IEC 750	K
Equipment marking acc. to DIN EN 61346-2	K





Ambient conditions:	
Ambient temperature	-20 ... +70 °C
• during operation	

Installation/ mounting/ dimensions:	
Diameter of feed through opening	40 mm
Width	100 mm
Height	65 mm
Depth	85 mm

Mounting type

screw fixing

Certificates/ approvals:

General Product Approval	Declaration of Conformity	Test Certificates	other
 CSA	 UL	  EG-Konf.	<a href="#">Special Test Certificate</a> <a href="#">Miscellaneous</a>

other

[Confirmation](#)

Further information

**Information- and Downloadcenter (Catalogs, Brochures,...)**

<http://www.siemens.com/industrial-controls/catalogs>

**Industry Mall (Online ordering system)**

<http://www.siemens.com/industrymall>

**Cax online generator**

<http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UL2201-3A>

**Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**

<https://support.industry.siemens.com/cs/ww/en/ps/3UL2201-3A>

**Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)**

[http://www.automation.siemens.com/bilddb/cax\\_de.aspx?mlfb=3UL2201-3A&lang=en](http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UL2201-3A&lang=en)

last modified:

07/07/2017