SIEMENS

Data sheet

6GK7277-1AA00-0AA0

Product type designation



CSM 1277

COMPACT SWITCH MODULE CSM 1277 CONNECTION SIMATIC S7-1200 AND UP TO 3 ADDIT. DEVICES TO IND. ETHERNET W. 10/100 MBIT/S UNMANAGED SWITCH, 4 RJ45 PORTS, EXT. 24V DC POWER SUPPLY LED DIAGNOS., S7-1200 MODULE INCL. MANUAL ON CD

Transmission rate	
Transfer rate	10 Mbit/s, 100 Mbit/s
Interfaces / for communication / integrated	
Number of electrical connections	
 for network components or terminal equipment 	4
Number of 100 Mbit/s SC ports	
• for multimode	0
Number of 1000 Mbit/s LC ports	
• for multimode	0
• for single mode (LD)	0
Interfaces / others	
Number of electrical connections	
• for power supply	1
Type of electrical connection	
• for power supply	3-pole terminal block
Supply voltage, current consumption, power loss	
Type of voltage / of the supply voltage	DC

Supply voltage	
• external	24 V
• external	19.2 28.8 V
Product component / fusing at power supply input	Yes
Fuse protection type / at input for supply voltage	0.5 A / 60 V
Consumed current / maximum	0.07 A
Power loss [W]	
• at DC / at 24 V	1.6 W

Permitted ambient conditions	
Ambient temperature	
 during operation 	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
Relative humidity	
 at 25 °C / without condensation / during operation / maximum 	95 %
Protection class IP	IP20

Design, dimensions and weight	
Design	SIMATIC S7-1200 device design
Width	45 mm
Height	100 mm
Depth	75 mm
Net weight	0.15 kg
Mounting type	
• 35 mm DIN rail mounting	Yes
• wall mounting	Yes
• S7-300 rail mounting	No
 S7-1500 rail mounting 	No

Product functions / management, configuration	
Product function	
 multiport mirroring 	No
switch-managed	No

Standards, specifications, approvals	
Standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T, CL.1, Zone 2, GP. IIC, T Ta
• for hazardous zone	EN 600079-15:2005, EN 600079-0:2006, II 3 G Ex nA II T4, KEMA 08 ATEX 0003 X
 for safety / from CSA and UL 	UL 508, CSA C22.2 No. 142
• for emitted interference	EN 61000-6-4:2007
• for interference immunity	EN 61000-6-2:2005

Certificate of suitability / CE marking	Yes
Certificate of suitability	EN 61000-6-2:2005, EN 61000-6-4:2007
• C-Tick	Yes
KC approval	No
Marine classification association	
 American Bureau of Shipping Europe Ltd. (ABS) 	Yes
Bureau Veritas (BV)	Yes
Det Norske Veritas (DNV)	Yes
Germanische Lloyd (GL)	No
 Lloyds Register of Shipping (LRS) 	Yes
 Nippon Kaiji Kyokai (NK) 	Yes
 Polski Rejestr Statkow (PRS) 	No
 Royal Institution of Naval Architects (RINA) 	No
MTBF / at 40 °C	273 y

Further Information / Internet Links

Internet-Link

• to website: Selector SIMATIC NET SELECTION TOOL

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx Download Manager

• to website: Industry Online Support

http://www.siemens.com/snst

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/industry/infocenter

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

Security information

Security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit

last modified: 06/15/2017

http://support.automation.siemens.com. (V3.4)